



Aaron Small
City of Williamsburg
401 Lafayette Street
Williamsburg, VA 23185

January 12, 2023

Re: HRSD Flow Acceptance Certificate for the Greenwood Village project – City of Williamsburg (HRSD File No. 5132)

Dear Mr. Small,

This letter pertains to the Greenwood Village project, submitted to this office on August 25, 2022. Based on the project plans and the submitted wastewater design flow submitted by Timmons Group, HRSD **accepts** the flow from this project into its interceptor system for transmission and treatment.

This Flow Acceptance Certificate is based on the following project design parameters:

- An average daily flow (ADF) of **46,810 gpd** with a daily peak hour flow of **117,025 gpd**;
- The project calls for the construction of 151 Townhomes at Northridge Street;
- Sanitary sewer flows from this project will be conveyed to the city's existing gravity collection system, which is part of WILL-PS-016;
- No upgrades for the receiving pump station facility were submitted with this project; and,
- Flows from this project will enter the HRSD interceptor force main, NF-005, near the intersection of Quarterpath Road and Humelsine Parkway.

Should any of these attributes change, a revised flow acceptance request must be submitted, and the project will be subject to a re-approval process at HRSD. In addition, due to the location of this project and its distance from any HRSD infrastructure, no site plan comments are provided at this time.

This Flow Acceptance Certificate is good for a period of **five years** from the date of issuance provided that the site plan approval for the project is current. If the project has not been constructed within that time, this flow acceptance will be null and void. HRSD makes no representation with regards to Williamsburg's ability to accept the wastewater flow from this project.

Please feel free to contact me at rmartz@hrsd.com should you have any questions or concerns regarding this project.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Robert Martz', is written over a light blue circular stamp.

Robert Martz, P.E.
Hydraulic Analysis Manager

Cc:

Jack Bloom, P.E., Timmons Group (via email)

PO Box 5911, Virginia Beach, VA 23471-0911 • 757.460.2261 • Fax 757.363.7917